

# Evidence of Performance

## Thermal transmittance

Test report  
No. 11-000887-PR01  
(A01-06-en-01)




Client AKPA ALÜMINYUM PLS.  
SAN.VE TIC. LTD. STI  
Hürriyet Mh. Dr.Cemil Bengü  
34403 Istanbul  
Turkey

### Basis

EN ISO 12567-1: 2010  
Thermal performance of windows and doors - Determination of thermal transmittance by hot box method - Part 1: complete windows and doors

### Representation

(further cross sections see chapter 1.2)



Product	Single window with lateral fixed glazing
Designation	İZO WD 55
Overall dimensions (W x H in mm)	1,480 mm x 1,230 mm
(Frame) Material	Aluminium profile with thermal break
Type of opening	Turn
Infill panel	Insulating glass unit: Type: ISICAM klasik Configuration: 5 / 12 / 5 mm Gas filling: -- IR-Coating: -- Spacer: Aluminium
Special features	--

### Instructions for use

The present test report serves to demonstrate the thermal transmittance  $U_w$ .

### Validity

The data and results given relate solely to the tested and described specimen.

Testing thermal transmittance does not allow any statement to be made on any further characteristics relevant to performance and quality of the present construction.

### Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract.

### Contents

The report contains a total of 8 pages.

- 1 Object
- 2 Procedure
- 3 Detailed results

### Thermal transmittance



$$U_w = 2.9 \text{ W/(m}^2 \cdot \text{K)}$$

ift Rosenheim  
29 June 2011

Joachim Hessinger, Dipl.-Phys  
Head of Testing Department  
Building Physics

Konrad Huber  
Deputy Head of Testing Department  
Building Physics



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
  
DAP-PL-0808 99  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-60